



To: Interested Vendors

From: Johnna Harrell, Accounting Assistant

Date: October 1, 2020

Re: **ADDENDUM 10.01.20** to Invitation to Bid Electrical Upgrades at Cherokee Park (2020-09)

Please see the attached **ADDENDUM 10.01.20** to the Invitation to Bid Electrical Upgrades at Cherokee Park.

Thank you!

Attachment

Bill Brittain, County Mayor

511 West Second North Street • Morristown, TN 37814 • *office.* 423.586.1931 • *fax.* 423.585.4699

www.HamblenCountyTN.gov • *email.* bbrittain@co.hamblen.tn.us



ADDENDUM 10.01.20 to:

Invitation to Bid – Electrical Upgrades at Cherokee Park (2020-09)

Date of Addendum 10.01.20: October 01, 2020
Date of ITB Issuance: September 29, 2020
ITB Due Date: October 9, 2020 at 2p.m.

CHANGES:

1) SCOPE OF SERVICES A:

CHANGED TO THE FOLLOWING:

Existing Conduit:

The existing conduit feeding the electrical panels is 2". The Contractor may opt to re-use this existing conduit to feed the upgraded panels from the transformer. Contractor must field verify that the existing conduit is continuous from each panel to the transformer. Contractor to provide a per unit (per foot) deduct price for conduit and trenching indicated in the "Scope of Work" as a part of their bid.

2) COST PROPOSAL (page 31 of 35)

CHANGED TO THE FOLLOWING:

Request for alternate pricing for an additional panel.

Cost Proposed for: Upgrading one (1) additional 100-amp panel to a 200-amp panel. This additional panel is located near the Park Ranger's office at the entrance to the campground. All other stipulations listed in the "Scope of Work" and this addendum will apply to this add alternate.

END OF CHANGES per ADDENDUM 10.01.20. The remainder of the RFP REMAINS THE SAME.

Please acknowledge receipt of this ADDENDUM by including an original, signed copy with your response to this RFP.

Signature: _____
Printed Name: _____
Title: _____
Company: _____
Date: _____

Bill Brittain, County Mayor