

**\*Please make bid submissions as standard as possible without special fabrication\***

Could you please confirm the dimensions on the Handgun Lockers (Room AD118) and Locking Medical Cabinets (Room IP010) from Page 4 of the bid package? Also, are those items to be wall mounted or set on a counter or shelf unit?

**Handgun Lockers: Standard Size / 20 Lockers – Wall Mounted**

**Medical Cabinets: 6 ½' H x 4'W x 15" D Shelf Unit**

Are partial bids acceptable? **Yes**

#1 – General Areas (High Density System).

1. Regarding the rail / floor portion of this system; typically, systems include subfloor decking between rails and ramp at front, which is then covered by the client with carpet or vct. tile after installation. Can you confirm if this system should include sub floor decking / ramp, or will floorless rail systems be acceptable? **There is no pre-preparation for the floor system – it will mount to a flat concrete floor.**
2. Please confirm the desired overall height of the system, number of shelf openings per section as well as the number of dividers (if any) per shelf? **Adjustable, as high to ceiling as feasible.**
3. Please confirm if reference shelves are needed and if so, how many per carriage? **Yes, unknown number at this time.**
4. Please confirm if there are a total of 9 carriages – of which 2 will be lockable, or 7 carriages – of which 2 will be lockable. **7 carriages of which 2 will be lockable.**
5. Please confirm if all carriages should be 30" D, and are all carriages mobile type vs. partial being stationary platforms? **Yes. All mobile (Except the one most plan north in the space)**

1. On Page 3, regarding Installation, please confirm that you do not want your Mobile Tracks drilled and grouted. We manufacture both mounted and unmounted (removeable in future without drilling into flooring) High Density Mobile Filing Storage Systems. The previously installed System is fully grouted. It states installation methods that will not tear, unravel, or otherwise damage the flooring, is this under the High Density Mobile System and or for all Static Shelving and Cabinets? **Shelving and Cabinets.** Typically with High Density drilled and mounted storage systems are installed from the concrete up since decking will cover the flooring underneath. Is this High Density System to be installed on the approved slab on grade for the fully loaded weight? **Yes**

2. On Page 4, Item #1, please state the height of the Shelving **92" H** and number of openings per carriage **7** requested for the High Density Filing System. Are all shelves to be slotted, unslotted or some of each? **Some of each** If slotted where files will be stored, how many file dividers will be required per shelf? **3-4** It states an approximate Size System of 21' x 30', then 7

carriages 48"W x 30"D (Is this a typo meaning 30 feet deep?) **5 sections in each carriage measuring Approx 48"W x 30"D – some will be 15"D**. What length do you want the carriages? **Approximately 21' L** Also, what Length, Width and Height are required for the 2 Lockable Carriages to Store Confidential Files. **Within same specs as the rest of the system**. Are these files top tab or side tab? **Side tab** Do you want shelving with Doors or Cabinets **No**, locking on these two carriages? **Yes** Where do you want these two locking carriages placed on the System Design? **Plan north in the space**

What is the minimum aisle required for this High Density Mobile Filing System? **36 inches**

Are there any columns in the 21' x 30' area and is an aisle in front of this system? **No columns and yes.**

3. On Page 4, Item # 3, how many openings for the Open File Shelving? Are all shelves to be slotted, unslotted or some of each? If slotted where files will be stored, how many file dividers will be required per shelf? **Standard and adjustable**

4. On Page 4, Item# 4, how many openings of each Locking Medical Cabinets. Is there a picture of what is required? **No** Are dividers required? **Double doors, shelves no dividers**

5. On Page 4, Item # 5, what is the height, width and depth of the 4 drawer Cabinets? **Standard** Clearances would help. Is this 4 drawer file a Vertical file or lateral rollout with fixed or flipper doors? **Vertical** Are locks required? **No** Will Warrants be stored vertically in these cabinets and dividers needed? **Vertically, no dividers**. Do you have a size of items to be stored in this Cabinet? **Standard 8 ½ x 11** How are your warrants currently folded and filed? **Not folded, all vertical.**

6. On Page 4, Item# 6, What is the Height, Width and Length of each of the carriages and High Density Shelving System to be relocated. **92H x 30"W x 112"L** Are all carriages Mobile or Static? **All mobile**. What hours are available for disassembly and relocation? **Flexible with scheduling** Will relocation be slab on grade? **Yes**

7. On Page 4, Item # 7, how many openings are required? **7** Are Shelves to be unslotted (solid) or slotted? **Slotted** If slotted, how many file dividers per shelf? **Approximately three**

8. On Page 4, Item # 8, how many openings are required? Are Shelves to be unslotted(solid) or slotted? **Slotted** If slotted, how many file dividers per shelf? **3-4** Are Rooms CC115 and CC106 on the same floor? **Yes**

9. On Page 5, Item # 1, how many openings are required? **6** Do you want two Costumer Hanging Rods per unit or flat shelves? **Flat shelves** Are all units individual free standing or Initial Units with add-on units? **Add-ons**

10. On Page 5, Item # 2, how many openings are required? **20** How many shelves and gauge of steel? **4 shelves, standard gauge** Are all units individual free standing or Initial Units with add-on units? **Add-ons** If add-on Units, are steel side panels required? **yes**

11. On Page 5, Item# 3, how many openings are required? **7** How many shelves and gauge of steel? **6, standard gauge** Are all units individual free standing with closed back panels **Yes** and also closed side panels **Yes** or Initial Units with add-on units? **Add-on units** If add-on Units, are steel side panels required? **Yes**

12. On Page 5, Item# 4, how many openings are required? **2** How many shelves and gauge of steel? **6, standard gauge** Are both units individual free standing or an Initial Unit with add-on unit? **Add-on unit**

13. Is there a CAD drawing available. **Yes, upon request.**

